

Dr. P. H. Umrigar  
(MBBS, DPH)  
Medical Officer of Health



Surat Municipal Corporation  
Muglisara,  
Surat – 395 003

No.PHD/PI/ 60  
Dt/4/05/2026

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by Mr. J.P.Raval, Sanitary Inspector from Health Department inspected **S.D. JAIN MODERN SCHOOL** situated at Vesu Char Rasta, U.M.Road, Vesu Surat on Dt.21/04/2026 and on the basis of Water Test report bearing number 01 dated 04/05/2026 of Surat Municipal Corporation (Public Health Laboratory) certified that the certified that the **S.D. JAIN MODERN SCHOOL** has Safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State govt.

**This certificate is valid till 31st December-2026..**

Dr. Pradeep H. Umrigar  
Medical Officer of Health  
Health Department  
Surat Municipal Corporation

To,  
Principal  
S.D. JAIN MODERN SCHOOL  
Vesu Char Rasta, Vesu,  
U.M. Road,  
Surat.





# Public Health Laboratory

Surat Municipal Corporation  
2<sup>nd</sup> Floor, Vesu Urban Community Health Center,  
Opp. Vesu Fire Station, VIP Road,  
Vesu, Surat - 395007 Gujarat

Name And Address of Applicant-	S. D. Jain Modern School Vesu, Char Rasta, Surat.			Report No.	No.Q-2/PHL/WC/E-1/2026-27
				Receipt No.	866032
				ULR No.	-
				Date of Sample	01/05/2026
Type of Sample:-	Private	Register Entry No.	1	Start Date of Analysis	04/05/2026
Source of the Water:-	Drinking Water			End Date of Analysis	04/05/2026

## Test Report

Sample Description :- A Plastic Bottle
Physical Appearance: - Clear Liquid

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.		Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.		Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.		6.7	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent.	Max. 0.5
6.	Nitrate (as NO <sub>3</sub> )	FSSAI Manual of Method-2016 Water Section A Method No.II.4	mg/l	Absent	Max. 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	25.0	Max. 250
8.	Total Alkalinity (as HCO <sub>3</sub> )	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	65.0	Max.200
9.	Total hardness (as CaCO <sub>3</sub> )	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	35.0	Max.200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	125.0	Max. 500

**Opinion:** With respect to the test and observation performed, above sample of Drinking Water conforms to the standards and provisions of Food Safety and Standard Act. 2006 and FSS Rules & Regulations.

.....end of the test report.....

Report Issue Date :- 12/05/2026



*A. Patel*  
Food Analyst  
Public Health Laboratory  
Surat Municipal Corporation  
Surat

Note:-  
♦ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.  
♦ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.